


CTR2 / CTR2-AD

CALIBRATION TARGET AND VERIFICATION ADAPTER FOR ESD



FOR TESTS ACCORDING TO ...

- > EN 61000-4-2
- > IEC 61000-4-2
- > ISO 10605

ESD CALIBRATION TARGET

The CTR 2 is a coaxial current target to monitor Electro Static Discharges built as required by EN/IEC 61000-4-2 Ed.2 standard. The target can be purchased as an option to the ESD generators, model dito or ESD 30. It can be used for measurements up to 30kV. Additional attenuators are available to match the output signal with the input capability of the oscilloscope.

HIGHLIGHTS

- > **Current target as per IEC/EN 61000-4-2**
- > **20ohm impedance +/- 5%**
- > **Test voltage up to 30kV**
- > **Insertion loss +/- 0.5dB up to 1GHz**
- > **Insertion loss +/- 1.2dB up to 4GHz**
- > **Includes 20dB attenuator and 1m cable RG400**
- > **Additional attenuators available (optional)**
- > **50ohm Adapter line CTR 2-AD available (option)**

APPLICATION AREAS



INDUSTRY



RESIDENTIAL



AUTOMOTIVE



AVIONICS



COMPONENTS



MILITARY



BROADCAST



MEDICAL



TELECOM

TECHNICAL DETAILS


VERIFICATION/CALIBRATION

VERIFICATION SET-UP FOR THE CTR 2 TARGET

The current target is verified to meet the required insertion loss of ± 0.5 dB up to 1 GHz and ± 1.2 dB up to 4 GHz.

In addition to the current monitor, a Huber&Suhner 2W/20dB attenuator with a 1m Huber&Suhner coaxial cable with type "RG400" connectors are used.

The ESD target, Attenuator A and Cable C form the so-called "Target-Attenuator-Cable" chain being calibrated in this set-up. Attenuators B and C may not be required.



CTR 2-AD 50 OHM CONICAL ADAPTER LINE

50 OHM ADAPTER LINE TO CALIBRATE THE CTR 2 TARGET

The 50ohm conical adapter line connects the 50ohm cable to the input of the CTR 2 target. Geometrically it smoothly expands from the diameter of the 50ohm coaxial cable to the diameter of the target. If the target is made such that the impedance calculated from the diameter ratio d/D (refer to figure A2 of the IEC/EN 61000-4-2 standard document) not being equal to 50, the target adapter line shall be made such that the outer diameter of its inner conductor equals the diameter of the inner electrode of the current target.


The impedance is calculated considering the dielectric constant of the material that fills the conical adapter line (typically air). The target adapter line shall show an impedance of 50ohm $\pm 2\%$ from DC to 4GHz. The reflection coefficient of two target adapter lines mounted face-to-face shall be better than 30dB up to 1GHz and better than 20dB up to 4GHz while the insertion loss shall be less than 0.3dB in the same configuration.



INSERTION LOSS

S21 MEASUREMENT OF THE CTR 2 TARGET

This figure gives the typical insertion loss characteristic of the "Target-Attenuator-Cable" chain.



TECHNICAL DETAILS

ESD WAVEFORM VERIFICATION

HOW TO VERIFY THE ESD PULSES?


EM TEST recommends the following equipment in line with the IEC/EN 61000-4-2 standards requirements:

- DSO with a bandwidth of at least 2GHz
- Faraday cage
- EM TEST CTR 2 target

Capturing the correct waveform with the scope can only be achieved with the proper settings of the DSO. The settings need to be made to measure pulses with +/-2kV, +/-4kV, +/-6kV and +/-8kV. Four parameters need to be measured at each voltage level:

- Initial peak current
- Rise time between 10% and 90% of the initial peak
- Current value at 30ns
- Current value at 60ns


The time domain for the initial peak and rise time measurement is recommended to be set to 1ns/Div. For the current measurement at 30ns and 60ns a setting of 10ns/Div is recommended as being appropriate.



MEASURING SET-UP

PULSE VERIFICATION SET-UP USING A SHIELDED ROOM

This figure illustrates the proper set-up of the measuring equipment, the CTR 2 target and the ESD generator to be verified. Please observe that the ground return cable shall be pulled backwards at its mid point to form a large loop. This is of high importance as the ground return cable may heavily influence the ESD pulses, especially at the measuring point at 30ns and 60ns. If this fact is not properly observed you may see oscillations on the scope disturbing the pulse characteristic.



HOW TO CALCULATE THE RATIO?

RELATIONSHIP BETWEEN PEAK CURRENT VALUE AND MEASURED PEAK VOLTAGE

Calculated from the impedance and attenuation values the following equation gives the proper ratio:

$$I_p = 5 \times V_m$$

where

V_m is the voltage signal measured by the DSO in Volt

V_1 is the voltage measured accross the CTR 2 target

I_p is the discharge current


Therefore

$$V_1 = 20\text{dB} \times V_m = 20\text{ohm} \times I_p$$

$$I_p = 20\text{dB} \times V_m / 20\text{ohm}$$

For example:

A discharge current of 7.5A will give a voltage reading of 1.5V on the DSO.



TECHNICAL DETAILS


TECHNICAL DATA

Measuring resistor	20hm $\pm$ 5%
Design	As per IEC 61000-4-2, Ed.2:2008 and EN 61000-4-2:2009
Installation	The target shall be mounted into the wall of a shielded room or into a metal plate of at least 1.2m x 1.2m size.
Output	Coaxial SMA connector
Attenuator	An additional attenuator must be connected to the output of the CTR 2 depending on the input capability of the oscilloscope.
Insertion loss	$\pm$ 0.5dB up to 1 GHz and $\pm$ 1.2dB up to 4GHz This must always be measured as a "Target-Attenuator-Cable" chain. The target itself must not be measured.
ESD test voltage	$\pm$ 30kV
Dimension	70mm (diameter) x 30mm
Weight CTR 2	Approx. 400g

OPTION

CTR 2-AD	50ohm adapter line for the verification of the CTR 2; 50ohm $\pm$ 2% up to 4GHz as per IEC/EN 61000-4-2
----------	--

COMPETENCE WHEREVER YOU ARE



CONTACT EM TEST DIRECTLY

Switzerland

AMETEK CTS GmbH > Sternenhofstraße 15 > 4153 Reinach > Switzerland
 Phone +41 (0)61 204 41 11 > Fax +41 (0)61 204 41 00
 Internet: www.ametek-cts.com > E-mail: sales.conducted.cts@ametek.com

Germany

AMETEK CTS Europe GmbH > Customer Care Center EMEA > Lünener Straße 211
 > 59174 Kamen > Germany
 Phone +49 (0) 2307 26070-0 > Fax +49 (0) 2307 17050
 Internet: www.ametek-cts.com > E-mail: info.cts.de@ametek.com

Poland

AMETEK CTS Europe GmbH > Biuro w Polsce > ul. Twarda 44 > 00-831 Warsaw > Poland
 Phone +48 (0) 518 643 12
 Internet: www.ametek-cts.com > E-mail: Infopolska.cts@ametek.com

USA / Canada

AMETEK CTS US > 52 Mayfield Ave > Edison > NJ 08837 > USA
 Phone +1 732 417 0501
 Internet: www.ametek-cts.com > E-mail: usasales.cts@ametek.com

P.R. China

AMETEK Commercial Enterprise (Shanghai) Co. Ltd. > Beijing Branch > Western Section, 2nd floor > Jing Dong Fang Building (B10) > Chaoyang District > Beijing, China, 100015
 Phone +86 10 8526 2111 > Fax +86 (0)10 82 67 62 38
 Internet: www.ametek-cts.com > E-mail: chinasales@ametek.com

Republic of Korea

EM TEST Korea Limited > #405 > WooYeon Plaza > #986-8 > YoungDeok-dong > Giheung-gu > Yongin-si > Gyeonggi-do > Korea
 Phone +82 (31) 216 8616 > Fax +82 (31) 216 8616
 Internet: www.emtest.co.kr > E-mail: sales@emtest.co.kr

Singapore

AMETEK Singapore Pte. Ltd > No. 43 Changi South Avenue 2 > 04-01 Singapore 48164
 Internet: www.ametek-cts.com > E-mail: singaporesales.cts@ametek.com

Great Britain

AMETEK GB > 5 Ashville Way > Molly Millars Lane > Wokingham > Berkshire RG41 2 PL > Great Britain
 Phone +44 845 074 0660
 Internet: www.ametek-cts.com

Information about scope of delivery, visual design and technical data correspond with the state of development at time of release. Subject to change without further notice.