

SAFETY DATA SHEET

1. Identification

Product identifier	LPS® FOODLUBE Sugar Dissolving Fluid (Aerosol)
Other means of identification Part Number	57716
Recommended use	A sugar dissolving solution.
Recommended restrictions	None known.
Manufacturer/Importer/Supplier/	Distributor information
Manufacturer	
Manufacturer	
Company name	ITW Pro Brands
Address	4647 Hugh Howell Rd.
	Tucker, GA 30084
Country	(U.S.A.)
	Tel: +1 770-243-8800
In Case of Emergency	1-800-424-9300 (inside U.S.)
	+001 703-527-3887 (outside U.S.)
Website	www.lpslabs.com
E-mail	lpssds@itwprobrands.com

2. Hazard(s) identification

Physical hazards	Flammable aerosols	Category 2
	Gases under pressure	Liquefied gas
Health hazards	Not classified.	
Environmental hazards	Not classified.	
OSHA defined hazards	Not classified.	
Label elements		



Signal word	Warning
Hazard statement	Flammable aerosol. Contains gas under pressure; may explode if heated.
Precautionary statement	
Prevention	Keep away from heat/sparks/open flames/hot surfaces No smoking. Do not spray on an open flame or other ignition source. Pressurized container: Do not pierce or burn, even after use.
Response	Wash hands after handling.
Storage	Store in a well-ventilated place. Protect from sunlight. Do not expose to temperatures exceeding 50°C/122°F.
Disposal	Dispose of waste and residues in accordance with local authority requirements.
Hazard(s) not otherwise classified (HNOC)	None known.
Supplemental information	None.

3. Composition/information on ingredients

Mixtures

5. Fire-fighting measures Suitable extinguishing media Water fog. Foam. Dry chemical powder. Carbon dioxide (CO2). Unsuitable extinguishing media Do not use water jet as an extinguisher, as this will spread the fire. Specific hazards arising from the chemical Contents under pressure. Pressurized container may explode when exposed to heat or flam During fire, gases hazardous to health may be formed. Specific hazards arising from the chemical Firefighters must use standard protective equipment including flame retardant coat, helmet to face shield, gloves, rubber boots, and in enclosed spaces, SCBA. Firefighting In case of fire: Stop leak if safe to do so. Fight fire from maximum distance or use unmanner holders or monitor nozzles. Move containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up. Specific methods Use standard firefighting procedures and consider the hazards of other involved materials. N containers from fire area if you can do so without risk. Cool containers exposed to flames wi water until well after the fire is out. In the event of fire and/or explosion do not breathe fumes 6. Accidental release measures Keep unnecessary personnel away. Keep people away from and upwind of spill/leak. Keep for waras. Many gases are heavier than air and will spread along ground and collect in low or offined areas (sewers, basements, tanks). Wear appropriate protective equipment. Do not to damaged containers or spilled material unless wearing appropriate protective equipment. Do not of damaged containers or spilled material shor sor fisk. Isolate area until gas has disperesed.	Chemical name	Common name and synonyms	CAS number	%
halation Move to fresh air. Call a physician if symptoms develop or persist. kin contact No adverse effects due to skin contact are expected. kye contact No specific first aid measures noted. ngestion Not likely, due to the form of the product. Aost important Direct contact with eyes may cause temporary irritation. symptoms/effects, acute and lelayed Provide general supportive measures and treat symptomatically. edical attention and special reatment needed Ensure that medical personnel are aware of the material(s) involved, and take precautions to protect themselves. 5. Fire-fighting measures Water fog. Foam. Dry chemical powder. Carbon dioxide (CO2). Do not use water jet as an extinguishing nedia Contents under pressure. Pressurized container may explode when exposed to heat or flam During fire, gases hazardous to health may be formed. specific hazards arising from the chemical Firefightors specific methods Uses standard protective equipment including flame retardant coat, helmet to act shield, gloves, rubber boots, and in enclosed spaces, SCBA. specific methods Uses standard firefighting procedures and consider the hazards of other involved materials. N containers should be cooled with water to prevent vapor pressure build up. specific methods Uses tother is out. In the reas if you can do so without risk. Containers should be cooled with water pressurized containers may explode when expt			68476-86-8	1 - 5
skin contact No adverse effects due to skin contact are expected. kye contact No specific first aid measures noted. ngestion Not likely, due to the form of the product. Additional Section of immediate nedical attention and special reatment needed Direct contact with eyes may cause temporary irritation. Section of immediate nedical attention and special reatment needed Provide general supportive measures and treat symptomatically. Statistic Section of immediate nedical attention and special reatment needed Provide general supportive measures and treat symptomatically. Section of immediate nedical attention and special reatment needed Provide general supportive measures and treat symptomatically. Statistic Extinguishing media Suitable extinguishing media specific hazards arising from he chemical specific protective equipment in dprecautions for firefighters Water fog. Foam. Dry chemical powder. Carbon dioxide (CO2). Do not use water jet as an extinguisher, as this will spread the fire. Contents under pressure. Pressurized container may explode when exposed to heat or flam During fire, gases hazardous to health may be formed. Specific methods Use standard firefighting procedures and oonsider the hazards of other involved materials. No containers should be cooled with water to prevent vapor pressure build up. Specific methods Use standard firefighting procedures and oonsider the hazards of other involved materials. Not actiser and materials for inortactive equipment and imeregency procedur	4. First-aid measures			
Eye contactNo specific first aid measures noted.IngestionNot likely, due to the form of the product.Most importantDirect contact with eyes may cause temporary irritation.Water for inmediateProvide general supportive measures and treat symptomatically.medical attention and specialProvide general supportive measures and treat symptomatically.Beneral informationEnsure that medical personnel are aware of the material(s) involved, and take precautions to protect themselves.5. Fire-fighting measuresWater fog. Foam. Dry chemical powder. Carbon dioxide (CO2). Do not use water jet as an extinguisher, as this will spread the fire.5. pecific hazards arising from he chemicalContents under pressure. Pressurized container may explode when exposed to heat or flam bigecial protective equipment ind precautions for firefightersFire fighting reguipment/instructionsIn case of fire: Stop leak if safe to do so. Fight fire from maximum distance or use unmanner holders or monitor nozeles. Move containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure dontainers exposed to flames wi water until well after the fire is out. In the event of fire and/or explosion do not breathe fumes6. Accidental release measuresNeep unnecessary personnel away. Keep people away from and upwind of splil/leak. Keep to heat or flame.7. Accidental release measuresKeep unnecessary personnel away. Keep people away from and upwind of splil/leak. Keep to heat or flames in sould be container form fire areal protective equipment and due direfighting guapment. Local authorities should be advised if significant splilg containers for maxima protection recommended in Section 8 o	nhalation	Move to fresh air. Call a physician if symptom	s develop or persist.	
negestionNot likely, due to the form of the product.Most important (symptoms/effects, acute and lelayedDirect contact with eyes may cause temporary irritation.Motication of immediate necical attention and special reatment neededProvide general supportive measures and treat symptomatically.Beneral informationEnsure that medical personnel are aware of the material(s) involved, and take precautions to protect themselves.5. Fire-fighting measuresWater fog. Foam. Dry chemical powder. Carbon dioxide (CO2). Do not use water jet as an extinguisher, as this will spread the fire. Contents under pressure. Pressurized container may explode when exposed to heat or flam During fire, gases hazardous to health may be formed.Specific hazards arising from he chemicalContents under pressure. Pressurized container form file area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up.Specific methodsUse standard firelighting rise area if you can do so without risk. Col containers from fire area if you can do so without risk. Col containers movide materials. I containers from fire area if you can do so without risk. Col containers may explode when explosed to flames wi water until well after the fire is out. In the event of fire and/or explosion do not breathe fumes to heat or flame.Specific methodsKeep unnecessary personnel away. Keep people away from and upwind of splil/leak. Keep, rontective equipment and uning clean-up. Emergency personnel need self-contained breathing equipment. Do not to damaged containers or spliled material unless waaring appropriate protective equipment and of containers or spliled material unless waaring appropriate protective equipment and of containers or spliled material un	Skin contact	No adverse effects due to skin contact are ex	pected.	
Oost important symptoms/effects, acute and lelayed Direct contact with eyes may cause temporary irritation. Indication of immediate nedical attention and special reatment needed Provide general supportive measures and treat symptomatically. Seneral information Ensure that medical personnel are aware of the material(s) involved, and take precautions to protect themselves. 5. Fire-fighting measures Suitable extinguishing media medical Water fog. Foam. Dry chemical powder. Carbon dioxide (CO2). Do not use water jet as an extinguisher, as this will spread the fire. Contents under pressure. Pressurized container may explode when exposed to heat or flam During fire, gases hazardous to health may be formed. Specific natards arising from he chemical Contents under pressure. Pressurized container may explode when exposed to heat or flam During fire, gases hazardous to do so. Fight fire from maximum distance or use unmanne holders or monitor nozzles. Move containers from fire areal you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up. Specific methods Use standard firelighting procedures and consider the hazards of other involved materials. N containers should be cooled with water to prevent vapor pressure build up. Specific methods Use standard firelighting procedures and consider the hazards of other involved materials. N containers should be acooled with water to pressure and you can do so without risk. Cool containers exposed to flames wi water until well after the fire is out. In the event of fire and/or explosion do not breathe funge theat or flam	Eye contact	No specific first aid measures noted.		
symptoms/effects, acute and lelayed Provide general supportive measures and treat symptomatically. nedication of immediate nedical attention and special reatment needed Provide general supportive measures and treat symptomatically. Seneral information Ensure that medical personnel are aware of the material(s) involved, and take precautions to protect themselves. 5. Fire-fighting measures Water fog. Foam. Dry chemical powder. Carbon dioxide (CO2). Jusuitable extinguishing media Water fog. Foam. Dry chemical powder. Carbon dioxide (CO2). Jonedia Do not use water jet as an extinguisher, as this will spread the fire. specific hazards arising from he chemical Contents under pressure. Pressurized container may explode when exposed to heat or flam During fire, gases hazardous to health may be formed. Firefighting riguipment/instructions In case of fire: Stop leak if safe to do so. Fight fire from maximum distance or use unmanne holders or monitor nozzles. Move containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up. Specific methods Use standard firefighting procedures and consider the hazards of other involved materials. No containers from fire area if you can do so without risk. Cool containers exposed to flames wi water until well after the fire is out. In the event of fire and/or explosion do not breathe fumes to heat or flame. S. Accidental release measures Keep unnecessary personnel away. Keep people away from and upwind of spill/leak. Keep onfined areas (sewer	ngestion	Not likely, due to the form of the product.		
medical attention and special Ensure that medical personnel are aware of the material(s) involved, and take precautions to protect themselves. 5. Fire-fighting measures Suitable extinguishing media Water fog. Foam. Dry chemical powder. Carbon dioxide (CO2). Densuitable extinguishing media Water fog. Foam. Dry chemical powder. Carbon dioxide (CO2). Do not use water jet as an extinguisher, as this will spread the fire. Specific hazards arising from he chemical Contents under pressure. Pressurized container may explode when exposed to heat or flam. During fire, gases hazardous to health may be formed. Specific nations for firefighters Firefighters must use standard protective equipment including flame retardant coat, helmet virace shield, gloves, rubber boots, and in enclosed spaces, SCBA. Specific methods In case of fire: Stop leak if safe to do so. Fight fire from maximum distance or use unmanner holders or monitor nozles. Move containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up. Specific methods Use standard firefighting procedures and consider the hazards of other involved materials. N containers from fire area if you can do so without risk. Containers should be cooled with water to pressurized containers may or pressure build up. Specific methods Use standard firefighting procedures and consider the hazards of other involved materials. N containers from fire area if you can do so without risk. Cool containers should be acrosed speces before entering it and/or explosion do not breathe fumes of the acro fire area if you ca	symptoms/effects, acute and	Direct contact with eyes may cause temporary	y irritation.	
5. Fire-fighting measures Suitable extinguishing media Jusuitable extinguishing media Jusuitable extinguishing media Specific hazards arising from he chemical Specific hazards arising from he chemical Specific in protective equipment including flame retardant coat, helmet visual distance or use unmanner boots, and in enclosed spaces, SCBA. Firefighting Firefighters must use standard protective equipment including flame retardant coat, helmet visual distance or use unmanner holders or monitor nozzles. Move containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up. Specific methods Use standard firefighting procedures and consider the hazards of other involved materials. N containers from fire area if you can do so without risk. Cool containers exposed to flames wit water until well after the fire is out. In the event of fire and/or explosion do not breathe fumes Specific methods Keep unnecessary personnel away. Keep people away from and upwind of spill/leak. Keep of waares. Many gases are heavier than air and will spread along ground and collect in low of amaged containers or spilled material unless wearing appropriate protective exployment. Do not to damaged containers or spilled material unless wearing appropriate protective exployment. Do not to damaged containers or spilled material unless wearing appropriate protective exployment. Do not to damaged containers or spilled material lightion sources (no snoking, flares, so or flame sin immediate area). Keep combustibles (wood, paper, oil, etc.) away from spilled material spropriate protective ective ective exploped	nedical attention and special	Provide general supportive measures and trea	at symptomatically.	
Suitable extinguishing mediaWater fog. Foam. Dry chemical powder. Carbon dioxide (CO2).Jnsuitable extinguishing mediaDo not use water jet as an extinguisher, as this will spread the fire.Specific hazards arising from he chemicalContents under pressure. Pressurized container may explode when exposed to heat or flam During fire, gases hazardous to health may be formed.Specific protective equipment and precautions for firefightersFirefighters must use standard protective equipment including flame retardant coat, helmet v face shield, gloves, rubber boots, and in enclosed spaces, SCBA.In case of fire: Stop leak if safe to do so. Fight fire from maximum distance or use unmanner holders or monitor nozzles. Move containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up.Use standard firefighting procedures and consider the hazards of other involved materials. N containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up.Use standard firefighting procedures and consider the hazards of other involved materials. N containers from fire area if you can do so without risk. Containers should be aerosol. Contents under pressure. Pressurized container may explode when exp to heat or flame.6. Accidental release measures Personal precautions, protective equipment and mergency proceduresKeep unnecessary personnel away. Keep people away from and upwind of spill/leak. Keep of low areas. Many gases are heavier than air and will spread along ground and collect in low confined areas (sewers, basements, tanks). Wear appropriate protective equipment and clead and get container or spilled material unless wearing appropriate protective clothing. Ve	General information		he material(s) involved, and t	ake precautions to
Insuitable extinguishing nediaDo not use water jet as an extinguisher, as this will spread the fire.Denot use water jet as an extinguisher, as this will spread the fire.Contents under pressure. Pressurized container may explode when exposed to heat or flam During fire, gases hazardous to health may be formed.Special protective equipment ind precautions for firefightersFirefighters must use standard protective equipment including flame retardant coat, helmet v face shield, gloves, rubber boots, and in enclosed spaces, SCBA.Specific methodsIn case of fire: Stop leak if safe to do so. Fight fire from maximum distance or use unmanner holders or monitor nozzles. Move containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up.Use standard firefighting rocedures and consider the hazards of other involved materials. N containers from fire area if you can do so without risk. Cool containers exposed to flames wi water until well after the fire is out. In the event of fire and/or explosion do not breath fumes flammable aerosol. Contents under pressure. Pressurized container may explode when exp to heat or flames.Specific methodsKeep unnecessary personnel away. Keep people away from and upwind of spill/leak. Keep of low areas. Many gases are heavier than air and will spread along ground and collect in low of containers or spilled material unless wearing appropriate protective clothing. Vent closed spaces before entering them. Local authorities should be advised if significant spilag cannot be contained. Use personal protection recommended in Section 8 of the SDS.Actional release measuresRefer to attached safety data sheets and/or instructions for use. Stop leak if you can do so v risk. Isolate area until gas has disper	5. Fire-fighting measures			
InediaSpecific hazards arising from he chemicalContents under pressure. Pressurized container may explode when exposed to heat or flame During fire, gases hazardous to health may be formed.Special protective equipment ind precautions for firefightersFirefighters must use standard protective equipment including flame retardant coat, helmet v face shield, gloves, rubber boots, and in enclosed spaces, SCBA.ind precautions equipment/instructionsIn case of fire: Stop leak if safe to do so. Fight fire from maximum distance or use unmanner holders or monitor nozzles. Move containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up.Specific methodsUse standard firefighting procedures and consider the hazards of other involved materials. N containers from fire area if you can do so without risk. Containers exposed to flames wi water until well after the fire is out. In the event of fire and/or explosion do not breathe fumes Flammable aerosol. Contents under pressure. Pressurized container may explode when exp to heat or flame.S. Accidental release measures Presonal precautions, protective equipment and emergency proceduresKeep unnecessary personnel away. Keep people away from and upwind of spill/leak. Keep o low areas. Many gases are heavier than air and will spread along ground and collect in low of during clean-up. Emergency personnel need self-contained breathing equipment. Do not too damaged containers or spilled material unless wearing appropriate protective equipment and closed spaces before entering them. Local authorities should be advised if significant spillag cannot be contained. Use personal protection recommended in Section 8 of the SDS.Methods and materials for containment and cleaning up <td>Suitable extinguishing media</td> <td>Water fog. Foam. Dry chemical powder. Carb</td> <td>on dioxide (CO2).</td> <td></td>	Suitable extinguishing media	Water fog. Foam. Dry chemical powder. Carb	on dioxide (CO2).	
he chemicalDuring fire, gases hazardous to health may be formed.ipecial protective equipmentFirefightersind precautions for firefightersFirefighters must use standard protective equipment including flame retardant coat, helmet we face shield, gloves, rubber boots, and in enclosed spaces, SCBA.in case of fire: Stop leak if safe to do so. Fight fire from maximum distance or use unmanneer holders or monitor nozzles. Move containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up.typecific methodsUse standard firefighting procedures and consider the hazards of other involved materials. No containers from fire area if you can do so without risk. Cool containers exposed to flames wit water until well after the fire is out. In the event of fire and/or explosion do not breathe fumesS. Accidental release measuresPersonal precautions, protective equipment and mergency proceduresMethods and materials for ontainer and cleaning upMethods and materials for ontainer and cleaning upRethods and materials for ontainer and cleaning upMethods and materials for<	C	Do not use water jet as an extinguisher, as th	is will spread the fire.	
Ind precautions for firefightersface shield, gloves, rubber boots, and in enclosed spaces, SCBA.Fire fighting equipment/instructionsIn case of fire: Stop leak if safe to do so. Fight fire from maximum distance or use unmanned holders or monitor nozzles. Move containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up.Specific methodsUse standard firefighting procedures and consider the hazards of other involved materials. N 				ed to heat or flam
 holders or monitor nozzles. Move containers from fire area if you can do so without risk. Containers should be cooled with water to prevent vapor pressure build up. Use standard firefighting procedures and consider the hazards of other involved materials. A containers from fire area if you can do so without risk. Cool containers exposed to flames with water until well after the fire is out. In the event of fire and/or explosion do not breathe fumes Flammable aerosol. Contents under pressure. Pressurized container may explode when explosion heat or flame. Accidental release measures Keep unnecessary personnel away. Keep people away from and upwind of spill/leak. Keep or low areas. Many gases are heavier than air and will spread along ground and collect in low confined areas (sewers, basements, tanks). Wear appropriate protective equipment. Do not to udamaged containers or spilled material unless wearing appropriate protective clothing. Venticosed spaces before entering them. Local authorities should be advised if significant spillag cannot be contained. Use personal protection recommended in Section 8 of the SDS. Refer to attached safety data sheets and/or instructions for use. Stop leak if you can do so w risk. Isolate area until gas has dispersed. Eliminate all ignition sources (no smoking, flares, so or flames in immediate area). Keep combustibles (wood, paper, oil, etc.) away from spilled material. Scoop up used absorbent into drums or other appropriate container. For waste disp see section 13 of the SDS. 				lant coat, helmet v
 Containers from fire area if you can do so without risk. Cool containers exposed to flames with water until well after the fire is out. In the event of fire and/or explosion do not breathe fumes Flammable aerosol. Contents under pressure. Pressurized container may explode when exploit to heat or flame. Accidental release measures Keep unnecessary personnel away. Keep people away from and upwind of spill/leak. Keep of low areas. Many gases are heavier than air and will spread along ground and collect in low of contined areas (sewers, basements, tanks). Wear appropriate protective equipment and during clean-up. Emergency procedures Methods and materials for containent and cleaning up Methods and materials for containent		holders or monitor nozzles. Move containers f	from fire area if you can do so	o without risk.
 6. Accidental release measures Personal precautions, protective equipment and emergency procedures Methods and materials for containment and cleaning up Methods cleaning up <li< td=""><td>Specific methods</td><td>containers from fire area if you can do so with</td><td>out risk. Cool containers exp</td><td>osed to flames wit</td></li<>	Specific methods	containers from fire area if you can do so with	out risk. Cool containers exp	osed to flames wit
 Personal precautions, protective equipment and emergency procedures Keep unnecessary personnel away. Keep people away from and upwind of spill/leak. Keep of low areas. Many gases are heavier than air and will spread along ground and collect in low of confined areas (sewers, basements, tanks). Wear appropriate protective equipment and cloud during clean-up. Emergency personnel need self-contained breathing equipment. Do not toud damaged containers or spilled material unless wearing appropriate protective clothing. Ventic closed spaces before entering them. Local authorities should be advised if significant spillage cannot be contained. Use personal protection recommended in Section 8 of the SDS. Refer to attached safety data sheets and/or instructions for use. Stop leak if you can do so we risk. Isolate area until gas has dispersed. Eliminate all ignition sources (no smoking, flares, so or flames in immediate area). Keep combustibles (wood, paper, oil, etc.) away from spilled material. Scoop up used absorbent into drums or other appropriate container. For waste disperse section 13 of the SDS. 	General fire hazards		Pressurized container may	explode when exp
 by areas. Many gases are heavier than air and will spread along ground and collect in low of confined areas (sewers, basements, tanks). Wear appropriate protective equipment and cloud during clean-up. Emergency personnel need self-contained breathing equipment. Do not toud damaged containers or spilled material unless wearing appropriate protective clothing. Ventic closed spaces before entering them. Local authorities should be advised if significant spillag cannot be contained. Use personal protection recommended in Section 8 of the SDS. Refer to attached safety data sheets and/or instructions for use. Stop leak if you can do so wrisk. Isolate area until gas has dispersed. Eliminate all ignition sources (no smoking, flares, so or flames in immediate area). Keep combustibles (wood, paper, oil, etc.) away from spilled material. Scoop up used absorbent into drums or other appropriate container. For waste disperse see section 13 of the SDS. 	6. Accidental release meas	sures		
containment and cleaning up risk. Isolate area until gas has dispersed. Eliminate all ignition sources (no smoking, flares, s or flames in immediate area). Keep combustibles (wood, paper, oil, etc.) away from spilled material. Scoop up used absorbent into drums or other appropriate container. For waste disp see section 13 of the SDS.	Personal precautions, protective equipment and emergency procedures	low areas. Many gases are heavier than air an confined areas (sewers, basements, tanks). V during clean-up. Emergency personnel need damaged containers or spilled material unless closed spaces before entering them. Local au	nd will spread along ground a Vear appropriate protective e self-contained breathing equi s wearing appropriate protect Ithorities should be advised if	and collect in low c quipment and clot pment. Do not tou ive clothing. Venti significant spillag
Environmental precautions Avoid discharge into drains, water courses or onto the ground.	Methods and materials for containment and cleaning up	risk. Isolate area until gas has dispersed. Elin or flames in immediate area). Keep combustit material. Scoop up used absorbent into drum	ninate all ignition sources (no bles (wood, paper, oil, etc.) a	smoking, flares, s way from spilled
	Environmental precautions	Avoid discharge into drains, water courses or	onto the ground.	
	7. Handling and storage			

Pressurized container: Do not pierce or burn, even after use. Do not use if spray button is missing Precautions for safe handling or defective. Do not spray on a naked flame or any other incandescent material. Do not smoke while using or until sprayed surface is thoroughly dry. Do not cut, weld, solder, drill, grind, or expose containers to heat, flame, sparks, or other sources of ignition. All equipment used when handling the product must be grounded. Avoid prolonged exposure. Use only in well-ventilated areas. Wear appropriate personal protective equipment. Observe good industrial hygiene practices.

Conditions for safe storage, including any incompatibilities

Pressurized container. Protect from sunlight and do not expose to temperatures exceeding 50°C/122 °F. Keep away from heat, sparks and open flame. This material can accumulate static charge which may cause spark and become an ignition source. Prevent electrostatic charge build-up by using common bonding and grounding techniques. Store in original tightly closed container. Store in a well-ventilated place. Stored containers should be periodically checked for general condition and leakage. Store away from incompatible materials (see Section 10 of the SDS).

8. Exposure controls/personal protection

No exposure limits noted for ingredient(s).		
No biological exposure limits noted for the ingredient(s).		
Good general ventilation (typically 10 air changes per hour) should be used. Ventilation rates should be matched to conditions. If applicable, use process enclosures, local exhaust ventilation, or other engineering controls to maintain airborne levels below recommended exposure limits. If exposure limits have not been established, maintain airborne levels to an acceptable level.		
Individual protection measures, such as personal protective equipment		
Wear safety glasses with side shields (or goggles).		

Skin protection Hand protection	Wear appropriate chemical resistant gloves. Suitable gloves can be recommended by the glove supplier.
Other	Wear suitable protective clothing.
Respiratory protection	In case of insufficient ventilation, wear suitable respiratory equipment.
Thermal hazards	Wear appropriate thermal protective clothing, when necessary.
General hygiene considerations	When using do not smoke. Always observe good personal hygiene measures, such as washing after handling the material and before eating, drinking, and/or smoking. Routinely wash work clothing and protective equipment to remove contaminants.

9. Physical and chemical properties

Appearance		
Physical state	Gas.	
Form	Aerosol.	
Color	Clear, Colorless.	
Odor	Mild.	
Odor threshold	Not available.	
рН	9 - 10	
Melting point/freezing point	Not available.	
Initial boiling point and boiling range	> 212 °F (> 100 °C)	
Flash point	-180.4 °F (-118.0 °C) Tag Closed Cup (propellant)	
Evaporation rate	1	
Flammability (solid, gas)	Not available.	
Upper/lower flammability or explosive limits		
Flammability limit - lower (%)	Not available.	
Flammability limit - upper (%)	Not available.	
Explosive limit - lower (%)	Not available.	
Explosive limit - upper (%)	Not available.	
Vapor pressure	< 1 mm Hg @ 20°C	
Vapor density	> 1	
Relative density	Not available.	
Solubility(ies)		
Solubility (water)	Soluble.	
Partition coefficient (n-octanol/water)	< 1	

Auto-ignition temperature	Not available.
Decomposition temperature	Not available.
Viscosity	Not available.
Other information	
Explosive properties	Not explosive.
Heat of combustion	< 20 kJ/g
Oxidizing properties	Not oxidizing.
Percent volatile	> 80 %
Specific gravity	1 - 1.1 @ 20°C
VOC	4 % per US State & Federal Consumer Product Regulations

10. Stability and reactivity

Reactivity	The product is stable and non-reactive under normal conditions of use, storage and transport.
Chemical stability	Material is stable under normal conditions.
Possibility of hazardous reactions	No dangerous reaction known under conditions of normal use.
Conditions to avoid	Heat. Avoid temperatures exceeding the flash point. Contact with incompatible materials.
Incompatible materials	Strong oxidizing agents.
Hazardous decomposition products	Carbon oxides.

11. Toxicological information

Information on likely routes of exposure

Inhalation	Prolonged inhalation may be harmful.
Skin contact	No adverse effects due to skin contact are expected.
Eye contact	Direct contact with eyes may cause temporary irritation.
Ingestion	Expected to be a low ingestion hazard.
Symptoms related to the physical, chemical and toxicological characteristics	Direct contact with eyes may cause temporary irritation.

Information on toxicological effects

Acute toxicity		
Components	Species	Test Results
Petroleum Gases, Liquiified, Swe	etened (CAS 68476-86-8)	
Acute		
Inhalation		
Gas		
LC50	Mouse	1237 mg/l, 120 Minutes
		52 %, 120 Minutes
LC50	Rat	1355 mg/l
Skin corrosion/irritation	Prolonged skin contact may cause temporary irritation.	
Serious eye damage/eye irritation	Direct contact with eyes may cause temporary irritation.	
Respiratory or skin sensitizatio	n	
Respiratory sensitization	Not a respiratory sensitizer.	
Skin sensitization	This product is not expected to cause skin sensitization.	
Germ cell mutagenicity	No data available to indicate product or any components present at greater than 0.1% are mutagenic or genotoxic.	
Carcinogenicity	This product is not considered to be a carcinogen by IARC, ACGIH, NTP, or OSHA.	
IARC Monographs. Overall Not listed.	Evaluation of Carcinogenicity	

OSHA Specifically Regulated Substances (29 CFR 1910.1001-1050)

Not regulated.

US. National Toxicology Program (NTP) Report on Carcinogens

Not listed.

Reproductive toxicity	This product is not expected to cause reproductive or developmental effects.
Specific target organ toxicity - single exposure	Not classified.
Specific target organ toxicity - repeated exposure	Not classified.
Aspiration hazard	Not likely, due to the form of the product.
Chronic effects	Prolonged inhalation may be harmful.
Further information	This product has no known adverse effect on human health.

12. Ecological information

Ecotoxicity

The product is not classified as environmentally hazardous. However, this does not exclude the possibility that large or frequent spills can have a harmful or damaging effect on the environment. No data is available on the degradability of this product.

Persistence and degradability Bioaccumulative potential

Partition coefficient n-octanol /	water (log Kow)
-----------------------------------	-----------------

LPS® FOODLUBE Sugar Dis	solving Fluid (Aerosol)	< 1
Mobility in soil	No data available.	
Other adverse effects	None known.	

13. Disposal considerations

Disposal instructions	Collect and reclaim or dispose in sealed containers at licensed waste disposal site. Contents under pressure. Do not puncture, incinerate or crush. Dispose of contents/container in accordance with local/regional/national/international regulations.
Local disposal regulations	Dispose in accordance with all applicable regulations.
Hazardous waste code	The waste code should be assigned in discussion between the user, the producer and the waste disposal company. D001: Waste Flammable material with a flash point <140 F D003: Waste Reactive material
Waste from residues / unused products	Dispose of in accordance with local regulations. Empty containers or liners may retain some product residues. This material and its container must be disposed of in a safe manner (see: Disposal instructions).
Contaminated packaging	Since emptied containers may retain product residue, follow label warnings even after container is emptied. Empty containers should be taken to an approved waste handling site for recycling or disposal. Do not re-use empty containers.

14. Transport information

DOT	
UN number	UN1950
UN proper shipping name	Aerosols, flammable
Transport hazard class(es)	
Class	2.1
Subsidiary risk	-
Label(s)	2.1
Packing group	Not applicable.
Special precautions for user	Read safety instructions, SDS and emergency procedures before handling.
Packaging exceptions	306
Packaging non bulk	None
Packaging bulk	None
ΙΑΤΑ	
UN number	UN1950
UN proper shipping name	Aerosols, flammable
Transport hazard class(es)	
Class	2.1

Subsidiary risk Packing group Not applicable. **Environmental hazards** No. **ERG Code** 10L Special precautions for user Read safety instructions, SDS and emergency procedures before handling. Other information Passenger and cargo Allowed with restrictions. aircraft Cargo aircraft only Allowed with restrictions. IMDG UN1950 **UN number** AEROSOLS, flammable UN proper shipping name Transport hazard class(es) Class 2.1 Subsidiary risk Packing group Not applicable. **Environmental hazards** Marine pollutant No. EmS F-D. S-U Special precautions for user Read safety instructions, SDS and emergency procedures before handling. Transport in bulk according to Not applicable. Annex II of MARPOL 73/78 and the IBC Code DOT



15. Regulatory information

US federal regulations

This product is a "Hazardous Chemical" as defined by the OSHA Hazard Communication Standard, 29 CFR 1910.1200.

 TSCA Section 12(b) Export Notification (40 CFR 707, Subpt. D) Not regulated.
 CERCLA Hazardous Substance List (40 CFR 302.4) Not listed.
 SARA 304 Emergency release notification Not regulated.
 OSHA Specifically Regulated Substances (29 CFR 1910.1001-1050) Not regulated.

Superfund Amendments and Reauthorization Act of 1986 (SARA)

Hazard	catogorias
nazaro	categories

Immediate Hazard - No Delayed Hazard - No Fire Hazard - Yes Pressure Hazard - Yes Reactivity Hazard - No

SARA 302 Extremely hazardous substance

Not listed.

SARA 311/312 Hazardous Yes chemical

SARA 313 (TRI reporting) Not regulated.

Other federal regulations

Clean Air Act (CAA) Section 112 Hazardous Air Pollutants (HAPs) List

Not regulated.

Clean Air Act (CAA) Section 112(r) Accidental Release Prevention (40 CFR 68.130)

Not regulated.

Safe Drinking Water Act Not regulated. (SDWA)

US state regulations

- US. California Controlled Substances. CA Department of Justice (California Health and Safety Code Section 11100) Not listed.
- US. California. Candidate Chemicals List. Safer Consumer Products Regulations (Cal. Code Regs, tit. 22, 69502.3, subd.
- (a))

Petroleum Gases, Liquiified, Sweetened (CAS 68476-86-8)

US. Massachusetts RTK - Substance List

Not regulated.

- US. New Jersey Worker and Community Right-to-Know Act Not listed.
- US. Pennsylvania Worker and Community Right-to-Know Law Not listed.
- US. Rhode Island RTK

Not regulated.

US. California Proposition 65

California Safe Drinking Water and Toxic Enforcement Act of 1986 (Proposition 65): This material is not known to contain any chemicals currently listed as carcinogens or reproductive toxins.

International Inventories

Country(s) or region	Inventory name	On inventory (yes/no)*
Australia	Australian Inventory of Chemical Substances (AICS)	Yes
Canada	Domestic Substances List (DSL)	Yes
Canada	Non-Domestic Substances List (NDSL)	No
China	Inventory of Existing Chemical Substances in China (IECSC)	Yes
Europe	European Inventory of Existing Commercial Chemical Substances (EINECS)	No
Europe	European List of Notified Chemical Substances (ELINCS)	No
Japan	Inventory of Existing and New Chemical Substances (ENCS)	No
Korea	Existing Chemicals List (ECL)	Yes
New Zealand	New Zealand Inventory	Yes
Philippines	Philippine Inventory of Chemicals and Chemical Substances (PICCS)	Yes
United States & Puerto Rico	Toxic Substances Control Act (TSCA) Inventory	Yes

*A "Yes" indicates that all components of this product comply with the inventory requirements administered by the governing country(s) A "No" indicates that one or more components of the product are not listed or exempt from listing on the inventory administered by the governing country(s).

16. Other information, including date of preparation or last revision

Issue date Version #	04-26-2016
version #	01
Disclaimer	ITW Pro Brands cannot anticipate all conditions under which this information and its product, or the products of other manufacturers in combination with its product, may be used. It is the user's responsibility to ensure safe conditions for handling, storage and disposal of the product, and to assume liability for loss, injury, damage or expense due to improper use. The information provided in this Safety Data Sheet is correct to the best of our knowledge, information and belief at the date of its publication. The information given is designed only as a guidance for safe handling, use, processing, storage, transportation, disposal and release and is not to be considered a warranty or quality specification. The information relates only to the specific material designated and may not be valid for such material used in combination with any other materials or in any process, unless specified in the text.